

2015 Water Quality Report Amendment – the information below is supplemental to the 2015 Consumer Confidence Report:

**Unregulated Contaminant Monitoring**

In 2015, the City monitored for Unregulated Contaminants for the Environmental Protection Agency (EPA) as part of a nation-wide study. Unregulated Contaminants are those that don't yet have a drinking water standard set by the EPA. The purpose of monitoring for these substances is to help the EPA decide whether the contaminants should have a standard.

Levels that are "<" are below the MRL (Minimum Reporting Level) set by the EPA. The MRL is considered the minimum amount that can be accurately detected by laboratory testing. Anything below the MRL is considered to be too small of an amount to be accurately detected and reported by a laboratory.

Since these substances are currently unregulated, the EPA has not set MCLs (Maximum Contaminant Levels) for them.

<b>Contaminant</b>	<b>Range Detected ppb</b>	<b>Average ppb</b>
PFBS	<0.09	<0.09
PFHpA	<0.01	<0.01
PFHxS	<0.03	<0.03
PFNA	<0.02	<0.02
PFOA	<0.02	<0.02
PFOS	<0.04	<0.04
Cobalt	<1.0	<1.0
Molybdenum	<1.0	<1.0
Strontium	55.8 - 78.5	64.2
Vanadium	8.2 - 11.5	9.48
Chromium (total)	<0.2 - 0.43	0.18
Chromium 6	0.068 - 0.37	0.169
Chlorate	<20.0 - 41.8	17.64
Bromochloromethane	<0.06	<0.06
Bromomethane	<0.2	<0.2
Chlorodifluoromethane	<0.08	<0.08
Chloromethane	<0.2	<0.2
1, 4-dioxane	<0.07	<0.07
1,1-dichloroethane	<0.03	<0.03
1, 2, 3-trichloropropane	<0.03	<0.03
1,3-butadiene	<0.1	<0.1